



No.F6/DFS/MS/School/SZ/2022/ 1142

Dated: 14/10/2022

FIRE SAFETY CERTIFICATE

Certified that the DAV Public School located at Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25, comprised of Basement + Ground + 02 upper floors was granted Fire Safety Certificate by this department vide letter no. - F6/DFS/MS/School/2018/SZ/2527 dated 14.11.2018. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 27.09.2022 in the presence of Dr. V.K. Barthwal (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and the building (Basement + Ground + 02 upper floors) is fit for occupancy of Group B "Educational Building" with effect from ..14..10..2022 renewed for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on...14..10..2022..at New Delhi by

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, DAV Public School located at Plot no. 3, Pocket 06, Jasola Vihar, New Delhi-25.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. Basement shall be used as per NBC/UBBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

Dr. V.K. BARTH WAL
Principal
D.A.V. PUBLIC SCHOOL
Plot No. 3, Pkt-6, Jasola Vihar
New Delhi-110 025